

REQUEST FOR INFORMATION

SITE PREP FOR MRI – PROJECT # 612A-14-014

Vendor Question 1: Enquiry on Missing Drawings

VA Response: 1) Amendment A00002 has been issued to incorporate all missing drawings and complete project specifications

2) A-001 does not exist

Vendor Question 2: General Plan Sheet G-102 references “Alternate #1” but the bid form does not address any alternates.

VA Response: There is no reference of “Alternate # 1” on the General Plan Sheet G-102 found. The solicitation does not address any “Alternate # 1” since none exists in this acquisition.

Vendor Question 3: Section 13 49 05-3, paragraph 2.2 MANUFACTURER A. 1.
Do you have contact information, point of contact/telephone number/email address, for ETS Lindgren supplier/distributor and would you please provide?

VA Response: The Government cannot recommend a vendor. Usually, a company’s contact information may be available at their web site.

Vendor Question 4: Section 13 49 05-3, paragraph 2.2 MANUFACTURER A. 1.
Have you previously reviewed as an equal products supplied by IMEDCO for the RF shielding requirement and if so was it considered an approved equal?

VA Response: Products that comply with the specification requirements may be approved as long as they meet the required performance as specified in the project documents and solicitation.

Vendor Question 5: Specification document VA261-16-R-0654 page 1 of 12, SCOPE OF WORK 1. GENERAL 1.1.2 Phase II
With respect to vacating the interior area adjacent to the new Phase I addition:

- a) Regarding the occupied interior space, what is the notification lead time for the space to be vacated and available for the installation of infection control measures and subsequent partial demolition?
- b) Who will be responsible for moving any furniture and/or equipment within the interior space?

c) Are there any fixtures which the contractor will be responsible for removing that the VA wishes to keep and not subject to disposal?

VA Response: a) Prior to NTP, VA will vacate interior area to be remodeled, and request IC Permit.

b) The Government will vacate the space before construction.

c) Contractor is responsible for removing and demolishing the work indicated in the demolition drawings.

Vendor Question 6: Is the work by the contractor at this federal facility exempt from state permitting requirements?

VA Response: No City Permit is required for general construction. Fire sprinklers shall be inspected and approved by Designing Fire Safety Engineer to comply with fire department code and requirements.